

CHECKLIST

5 Steps for Ordering Remanufactured Honeywell Pressure Transmitters

☐ Transmitter type

- Absolute (STA), Differential (STD), Gauge (STG), Fill System or Remote Seals (STR)

☐ Communication Protocol

- DE – DE option, specifically for Honeywell Communicators
- HART – HC option, check available Device Descriptions (DD) and any required revision levels
- AN – Analog Only may be available if no communication is required

☐ Sensor Range – Select appropriate *Range* based on *Span* needed for Calibration

- **Range** is the full capability of a selected sensor
- **Span** is the difference between upper and lower range values
- **Calibration** is the upper and lower range values needed
 - ☐ Request your Calibration when ordering
 - ☐ Full Range is the default if not supplied
- Best Practice
 - ☐ Select a **Range** that allows the **Span** to be somewhere mid-range, not at the extreme upper or lower end of its min and max values.
 - ☐ Span should not be “too small” – a percentage of a percentage will always be higher, so a large **Range** with a small **Span** can result in decreased accuracy.

Example: STD924

Range = 0-400 in. H2O

Span: URV-LRV=SPAN,
min span = 0-25 in. H2O
max span = 0-4000 in. H2O

Calibration:
0-200 in. H2O,
LRV = 0 in. H2O
URV = 200 in. H2O

☐ Options – Request when ordering per Model Code, including needed Materials for any *Process Wetted Parts*

- Sensor diaphragm (316, Hastelloy, Monel) and fill fluid (inert or silicone)
Process Wetted Parts
- Meter – SM or ZS– Smart Meter (SM option) or Zero Span board (ZS option)
- Flanges, Process Adaptors (per connection size), etc.
Process Wetted Parts
- Manifolds (Direct or Conventional)
Process Wetted Parts
- Mounting Hardware – Pipe, Panel, Direct, etc.

5 Steps for Ordering Remanufactured Honeywell Pressure Transmitters

- Fill Systems or Remote Seals built to specifications – Technical help for selection available on request
 - ☐ Process connections, material selection, and other specific transmitter or fill system specifications determine appropriate configuration – minimum specifications required:
 - ☐ Fill Fluid – DC200 Silicone, Neobee, etc.
 - ☐ Connection type – flush or capillary
 - ☐ Capillary length – enough so not taut, but avoid too many coils as well
 - ☐ Process Connection style – type of seal
 - ☐ Process Connection size
 - ☐ ANSI Rating
 - ☐ Material of Flange, Diaphragm, and Upper Housing
 - ☐ Optional Lower housing if needed
 - ☐ Calibration requires specifications for Maximum Process Level, Distance between process connections and transmitter, Specific gravity of Process Fluid & Fill Fluid to calculate
 - ☐ Any pictures of existing Fill Systems or Remote Seals can help determine specification needed
 - ☐ Additional technical support is available for selection, or help calculating calibration, and required on any special process conditions or configurations (such as Vacuum applications, Limited low end span, Closed Tank, Use of wet or dry leg with direct connect seal, etc.)

☐ **Optional configuration setups – Request when ordering or setup during commissioning of instrument**

- Display – units, % of span, dual, etc.
**factory default is set to Units
- Units – PSI, Inches H₂O, mmHg, etc.
**factory default is PSI, or units of any requested calibration
- Alerts/Alarms – set point deviation, over range, limits, cutoffs, etc.
**factory default to no special settings
- Dampening – adjustable time values for measurement updates
**factory default is 0.4 seconds
- Tagging – enter personalized Tag/Stock ID, Location, or other critical information
**factory default includes tagging if supplied

Any Questions or Technical Support Needed Call our Main Line: 800-325-4808